



# AMETRON

REFRIGERANTS

| Product Name                              | HCFC-R22  | Batch No.  | R22XG P20230403-03-1 |
|---|---|--|----------------------|
| Sample Source                             | Cylinder  | Sample Date  | 2023/04/03           |
| Test based on                             | AHRI 700-2017-2023  | Report Date  | 2023/04/03           |
| Item                                      | Specification   | Test Result  |                      |
| Appearance                                | Colorless transparent liquid,<br>No visible solid particles | Qualified  |                      |
| Purity, %                                 | ≥99.50  | 99.98  |                      |
| Moisture                                  | 10ppm   | 8ppm   |                      |
| Acidity (as HCL), %                       | 1ppm  | ≤0.1ppm  |                      |
| Evaporation residue, %                    | 0.01  | 0.005  |                      |
| Volume of non-condensable<br>gas (25°C) % | ≤1.5  | <1.5   |                      |
| Chloride (Cl <sup>-</sup> ) test          | No visible turbidity  | Pass   |                      |
| Test Results                              | Qualified   | <p>Inspection seal:</p>  <p>Note: This product is strictly prohibited for<br/>food and feed processing!!</p>  |                      |

Ametron International LLC, 16192 Coastal Highway Lewes, Delaware 19958 - USA.