



AMETRON


REFRIGERANTS

Product Name	HC-R290	Batch No.	R290XG P20230403-03-1
Sample Source	Cylinder	Sample Date	2023/04/03
Test based on	AHRI 700-2017-2023	Report Date	2023/04/03
Item	Specification	Test Result	
Appearance	Colorless transparent liquid, No visible solid particles	Qualified	
Purity, %	≥99.50	99.94	
Moisture	10ppm	7ppm	
Acidity (as HCL)	1ppm	<0.01ppm	
Evaporation residue, %	≤0.01	0.005	
sChloride (Cl ⁻) test	Pass	Pass	
Test Results	Qualified	<p>Inspection seal:</p>  <p>Note: This product is strictly prohibited for food and feed processing!!</p> 	

Ametron International LLC, 16192 Coastal Highway Lewes, Delaware 19958 - USA.

 www.ametronint.com

 sales@ametronint.com

 +1(628) 800 7167