



# AMETRON

REFRIGERANTS

Product Name	HCFC-R32	Batch No.	R32XG P20230403-03-1
Sample Source	Cylinder	Sample Date	2023/04/03
Test based on	AHRI 700-2017-2023	Report Date	2023/04/03
Item	Specification	Test Result	
Appearance	Colorless transparent liquid, No visible solid particles	Qualified	
Purity, %	≥99.9	99.93	
Moisture, %	≤0.0008	0.00071	
Acidity (as HCL), %	No	No	
Evaporation residue, %	≤0.0008	0.0007	
Volume of non-condensable gas (25°C) %	≤0.75	0.73	
Chloride (Cl <sup>-</sup> ) test	Pass	Pass	
Test Results	Qualified	<p>Inspection seal:</p>  <p>Note: This product is strictly prohibited for food and feed processing!!</p> 	

Ametron International LLC, 16192 Coastal Highway Lewes, Delaware 19958 - USA.