



# AMETRON

REFRIGERANTS

Product Name	HFC-R404A	Batch No.	R404AXG P20230403-03-1
Sample Source	Cylinder	Sample Date	2023/04/03
Test based on	AHRI 700-2017-2023	Report Date	2023/04/03
Item	Specification	Test Result	
Appearance	Colorless transparent liquid, No visible solid particles	Qualified	
Purity, %	≥99.50	99.95	
R125, %	42.0 - 46.0	44.43	
R143a, %	51.0 - 53.0	52.79	
R134a, %	2.0 - 6.0	3.10	
Moisture	10ppm	8.2ppm	
Acidity (asHCL)	1ppm	<0.1ppm	
Evaporation residue, %	≤0.01	≤0.01	
Chloride (Cl <sup>-</sup> ) test	No visible turbidity	Pass	
Test Results	Qualified	<p>Inspection seal:</p>  <p>Note: This product is strictly prohibited for food and feed processing!!</p> 	

Ametron International LLC, 16192 Coastal Highway Lewes, Delaware 19958 - USA.