



AMETRON

REFRIGERANTS

Product Name	HFC-R410a	Batch No.	R410aXG P20230403-03-1
Sample Source	Cylinder	Sample Date	2023/04/03
Test based on	AHRI 700-2017-2023	Report Date	2023/04/03
Item	Specification	Test Result	
Appearance	Colorless transparent liquid, No visible solid particles	Qualified	
Purity, %	≥99.50	99.93	
R32, %	48.5 - 50.5	49.61	
R125, %	49.5 - 51.5	51.12	
Moisture	10ppm	8ppm	
Acidity (as HCL)	1ppm	<0.1ppm	
Evaporation residue, %	0.01	≤0.01	
Non-condensable gas, max %	1.5	<1.5	
Chloride (Cl ⁻) test	No visible turbidity	Pass	
Test Results	Qualified	<p>Inspection seal:</p>  <p>Note: This product is strictly prohibited for food and feed processing!!</p> 	

Ametron International LLC, 16192 Coastal Highway Lewes, Delaware 19958 - USA.