

Product Name	HC-R600a		Batch No.	R600aXG P20230403-03-1		
Sample Source	Cylinder		Sample Date	2023/04/03		
Test based on AHRI 700-2		2017-2023 Report Date		2023/04/03		
Item		Specification		Test Result		
Appearance		Colorless transparent liquid, No visible solid particles		Qualified		
Purity, %		≥99.5		99.97		
Smell		No Sulfur Odor			Pass	
Moisture		10ppm		4	7ppm	
Acidity (as HCL)		1ppm		O.1ppm		
Evaporation residue, %		0.01			0.01	
Test Results		Qualified	Inspection seal:			
			Note: This product is strictly prohibited for			
			for	od and fe	ed processing!!	

Ametron International LLC, 16192 Coastal Highway Lewes, Delaware 19958 - USA.

ES OF AMERICA